



**ADDENDUM
PURCHASING OFFICE
CITY OF AUSTIN, TEXAS**

Solicitation: RFP 1100 TVN3007

Addendum No: 3

Date of Addendum: 06/19/2019

This addendum is to incorporate the following changes to the above referenced solicitation:

I. Addendum 2 is hereby rescinded.

II. Changes:

Section 0500, Scope of Work, has been updated to reflect the changes below.

a. The following has been added to Paragraph 1.0:

“by conducting annual surveys, and by maintaining the components of the CP system.”

b. Paragraph 3.1 is deleted in its entirety and replaced with:

3.1 Unit 5 segment (combined cycle):

3.1.1 An impressed current CP system with two air-cooled rectifiers, Rectifiers #1 & #2, with 25 distributed mixed metal oxide anodes arranged on three circuits where test stations 21 through 44 are installed along the piping routes for monitoring.

3.1.2 An impressed current CP system with one air-cooled rectifier, Rectifier #3, and deep anode groundbed used to supplement the current of the CP system described in item 3.1.1. The negative cable is connected to the closed cooling water supply piping.

3.1.3 An impressed current CP system with one air-cooled rectifier, Rectifier #4, and deep anode groundbed used to protect the fuel gas piping main header into the plant. The negative cable is connected to the 20-inch gas piping.

c. The reference to 3.1 in Paragraph 5.11 has been corrected to 5.1. The corrected sentence now reads:

“Each such survey shall include the elements listed in 5.1 above.”

III. ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.

ACKNOWLEDGED BY:

Name

Authorized Signature

Date

RETURN ONE COPY OF THIS ADDENDUM TO THE PURCHASING OFFICE, CITY OF AUSTIN, WITH YOUR RESPONSE OR PRIOR TO THE SOLICITATION CLOSING DATE. FAILURE TO DO SO MAY CONSTITUTE GROUNDS FOR REJECTION.