



# AEGION®

Stronger. Safer. Infrastructure.®

**corrpro®**

Austin Energy  
Sand Hill Energy Center – Del Valle, Texas  
2017 Annual Cathodic Protection Survey



Prepared for:  
Austin Energy, Sand Hill Energy Center  
Del Valle, TX  
**Corrpro Project No.: 340303589**  
14 February 2018

## QUALITY ASSURANCE FORM

<b>Project Identifier</b> 340303589			
<b>Project Name</b>	2017 Cathodic Protection (CP) Survey	<b>Type of Document</b>	Annual Survey
<b>Project Scope of Work</b>			
<ul style="list-style-type: none"> <li>• Test Cathodic Protection rectifiers for condition and operation.</li> <li>• Perform annual on and instant off survey for all the cathodic protection systems to ensure protective currents are being maintained on underground metallic piping and tanks for Units 1, 2, 3, 4, 5, 6 and 7.</li> </ul>			
<b>Referenced Standards for Compliance</b>			
<ul style="list-style-type: none"> <li>• NACE International Standard Practice SP0169-2013</li> <li>• NACE International Standard Practice SP0193-2016</li> <li>• NACE International Standard Practice SP00286-2007</li> <li>• NACE International Standard Test Method TM0497-2012</li> </ul>			
Compliance/Criteria Achieved?	47%	Test procedures documented?	Yes
Recommendations included?	Yes	Data Tables and/or Charts Included?	Yes
Compliant with Scope of Work?	Yes		
<b>Assumptions included in analysis</b>			
<ul style="list-style-type: none"> <li>• The utilities site plan is electrically continuous.</li> <li>• The CP systems and buried stationary reference cells are functioning properly.</li> </ul>			
<b>Corrpro Project Team</b>			
Project Manager – Alwynn Vanburen ( <a href="mailto:avanburen@aegion.com">avanburen@aegion.com</a> ) Corrosion Technician – Jeremy Taylor ( <a href="mailto:jtaylor@aegion.com">jtaylor@aegion.com</a> ) Corrosion Engineer – Shalini Dwarakapally ( <a href="mailto:sdwarakapally@aegion.com">sdwarakapally@aegion.com</a> ) Engineering Manager – Nick Judd ( <a href="mailto:njudd@aegion.com">njudd@aegion.com</a> )			
<b>Summary of conclusions</b>			
<ul style="list-style-type: none"> <li>• A total of 9 rectifiers provide 188.5 amps of protective current.</li> <li>• 32 of 68 (47 %) of potential readings gathered on this survey meet the NACE polarized potential criteria.</li> </ul>			
<b>Review completed by:</b>	Name	Nick Judd	
	Job Title	Engineering Manager	
	Qualifications	NACE Cathodic Protection Specialist #7987	
	Date	14 February 2018	

## REVISION HISTORY

---

Revision:	Date:	Status:	Approved by:
0	12/18/2017	Generate Report	Shalini Dwarakapally
0	12/19/2017	Peer Review	Alwynn VanBuren
0	02/14/2018	Approved for Final Release	Nick Judd

## EXECUTIVE SUMMARY

---

Corrpro was retained by Austin Energy to provide the cathodic protection (CP) comprehensive performance survey at Sand Hill Energy Center Del Valle, Texas. The survey was completed on November 30, 2017.

- A total of nine (9) rectifiers are providing a total of one hundred and eighty-eight (188) amps of protective current.
- From Unit 1 to 7, 32 of 68 (47%) of potential readings gathered on this survey meet the NACE polarized potential criteria.

Based on the findings from the 2017 annual CP survey, the following actions are recommended:

- Complete the missing potential measurements at Unit 6-7's test stations 13 and 15.
- For Units 1-4, only 6 out of the 26 test points are meeting the NACE polarized potential criteria. 4 of the 6 test points meeting the criteria are associated with the Fence. It is important to note that lines associated with Unit #1, #2, #3 and 4 are not meeting the NACE Criteria.
- Adjust the rectifier settings until the optimal cathodic protection current is achieved. It is recommended that bi-monthly surveys are conducted to ensure the optimal rectifier settings as the adjustments are made.
- Conduct bimonthly rectifier inspections (not to exceed 2.5-month intervals) to ensure continued operation and to establish cathodic protection for data trend analysis.
- Conduct an annual, instant-off cathodic protection survey to record polarized potential measurements.

The Corrpro Project Team includes:

- |   |  |              |
|---|--|--------------|
| • Project Manager –Alwynn Vanburen          | <a href="mailto:avanburen@aegion.com">avanburen@aegion.com</a>         | 713-460-6005 |
| • Corrosion Technician – Jeremy Taylor      | <a href="mailto:jtaylor@aegion.com">jtaylor@aegion.com</a>             | 346-237-5611 |
| • Corrosion Engineer – Shalini Dwarakapally | <a href="mailto:sdwarakapally@aegion.com">sdwarakapally@aegion.com</a> | 713-460-6062 |
| • Engineering Supervisor – Nick Judd        | <a href="mailto:njudd@aegion.com">njudd@aegion.com</a>                 | 713-460-6096 |

## TABLE OF CONTENTS

---

QUALITY ASSURANCE FORM .....	1
REVISION HISTORY.....	2
EXECUTIVE SUMMARY.....	3
1. INTRODUCTION .....	5
2. REFERENCED STANDARDS, DEFINITIONS AND ACRONYMS .....	5
3. CRITERIA OF PROTECTION .....	5
4. DESCRIPTION OF STRUCTURES .....	6
5. DESCRIPTION OF CATHODIC PROTECTION SYSTEMS .....	8
6. DATA AND FINDINGS .....	8
7. CONCLUSIONS .....	10
8. RECOMMENDATIONS .....	10

### **APPENDIX A** CP POWER SOURCE DATA

### **APPENDIX B** POTENTIAL MEASUREMENTS DATA

### **APPENDIX C** SITE WIDE MAPS

### **APPENDIX D** TESTING PROCEDURES

## 1. INTRODUCTION

---

Corrpro was retained by Austin Energy to provide the comprehensive cathodic protection survey report data collected by, a Corrosion Technician, Jeremy Taylor. The survey was completed on November 30, 2017.

This report discusses the data collected, conclusions and provides recommendation for all CP underground metallic piping and tanks for Units 1, 2, 3, 4, 5, 6 and 7.

## 2. REFERENCED STANDARDS, DEFINITIONS AND ACRONYMS

---

### Standards:

- NACE International Standard Practice SP0169-2013 – “Control of External Corrosion on Underground or Submerged Metallic Piping Systems”
- NACE International Standard Practice SP0193-2016 – “External Cathodic Protection of On-Grade Carbon Steel Storage Tank Bottoms”
- NACE International Standard Practice SP0286-2007 – “Electrical Isolation of Cathodically Protected Pipelines”
- NACE International Standard Test Method TM0497-2012 – “Measurement Techniques Related to Criteria for Cathodic Protection on Underground or Submerged Metallic Piping Systems”

### Definitions:

- Native Potential – Pipe-to-soil or structure-to-soil potential recorded before the cathodic protection current is applied
- On Potential – Pipe-to-soil or structure-to-soil potential recorded while the cathodic protection current is being applied
- Instant-Off Potential – Pipe-to-soil or structure-to-soil potential recorded immediately after the cathodic protection current is turned off (polarized potential)

### Acronyms:

- CP – Cathodic Protection
- CSE – Copper/Copper Sulfate Reference Electrode
- ICCP – Impressed Current Cathodic Protection
- STP – South Texas Project

## 3. CRITERIA OF PROTECTION

---

The following criteria are the basis for the cathodic protection survey presented.

Appropriate cathodic protection levels are determined in accordance with NACE SP0169-2013 and NACE SP0193-2016, which is a standardized set of criteria regarding pipe-to-soil and structure-to-soil potential measurements that evaluate the effectiveness of cathodic protection on metallic piping system. A structure is considered cathodically protected if:

1. Criteria that have been documented through empirical evidence to indicate corrosion control effectiveness on specific piping systems may be used on those piping systems or others with the same characteristics
2. A minimum of 100 mV of cathodic polarization. Either the formation or the decay of polarization must be measured to satisfy this criterion
3. A structure-to-electrolyte potential of -850mV or more negative as measured with respect to a saturated copper/copper sulfate (CSE) reference electrode. This potential may be either a direct measurement of the polarized potential or a current-applied potential. Interpretation of a current-applied measurement requires consideration of the significance of voltage drops in the earth and metallic paths

Appropriate procedures are determined in accordance with NACE SP0286-2007, which is a standardized set of practices regarding isolation of cathodically protected pipelines. These practices dictate that:


1. Pipelines to be cathodically protected must be isolated from other metallic structures unless the CP system has incorporated sufficient current drain for other structures
2. Electrical isolation can minimize or eliminate galvanic corrosion by dissimilar metals in contact with each other
3. A difference in potential of 100mV or greater to CSE can be observed across an isolation kit to confirm isolation. In absence of this an Isolation Kit tester may be used

#### **4. DESCRIPTION OF STRUCTURES**

---

Austin Energy's CP system, at Sand Hill Energy center in Del Valle, TX. The ICCP system with air cooled rectifiers in place are required to protect all underground metallic piping and tanks for Unit 1-4, Unit 5, and Unit 6-7. The utilities site plan general arrangement is shown in Figure 1 below:





**Figure 1: Utilities Site Plan General Arrangement**



## 5. DESCRIPTION OF CATHODIC PROTECTION SYSTEMS

The ICCP system consists of 9 rectifiers with deep and distributed anode groundbeds.

- Unit 1 to 4 – Four (4) air-cooled rectifiers with deep anode ground bed.
- Unit 5 – Four (4) air-cooled rectifiers - Rectifier #1 & #2 with distributed groundbed and Rectifier #3 & #4 with deep anode groundbed.
- Unit 6 to 7 – One (1) air-cooled rectifier with deep anode ground bed.

The list of the rectifiers providing CP inside the Utilities site plan is provided in Table 1 below:

**Table 1: Description of the Cathodic Protection Systems**

Rectifier ID.	Serial No.	Operational Status
R-1 Unit 5	1456UO403	Operating
R-2 Unit 5	30776	Operating
R3- Unit 5	153041	Operating
R4-Unit 5	160072	Operating
R1 Unit6-7	92666	Operating
R-1 Unit 1	153722	Operating
R-2 Unit 2	1458UO403	Operating
R-3 Unit 3	1457UO403	Operating
R-4 Unit 4	153721	Operating

## 6. DATA AND FINDINGS

A total of nine (9) cathodic protection rectifiers were tested and inspected:


- To assess the operating conditions
- For physical or electrical abnormalities due to damage
- To verify onboard DC meter operation.

The nine (9) rectifiers are providing a total of one hundred and eighty-eight (188) amps of protective current. Below are the key findings from the survey:

- Units 1-4, only 6 out of the 26 test points are meeting the NACE polarized potential criteria. 4 of the 6 test points meeting the criteria are associated with the Fence. It is important to note that lines associated with Unit #1, #2, #3 and 4 are not meeting the NACE Criteria.
- Fuel gas Isolation kit on Unit 1 to 4 is in good condition.

- Unit 5 test stations #27, #33 & #37 are meeting the 100-mV polarized potential but not the -850-mV polarized potential criteria.
- The three ICCP rectifiers – R-1 Unit 1, R-2 Unit 1, R-3 Unit 1 produced a total of 116.7 amps of cathodic protection current.
- The two ICCP rectifiers – R-4 Unit 5, R-1 Unit 6-7 produced a total of 2.3 amps of cathodic protection current.
- Test lead is broken at the Unit 5 Test station #43.
- Unit 6 to 7 test station #13 and #14 missing the potential measurements and the information is inaccessible and non-readable.

The rectifier datasheets are presented in Appendix A, and the rectifier output summary is presented in Figure below:



Potential measurements were taken at sixty-eight (68) test points as required per survey. The accepted criteria follows NACE polarized potential criteria. The polarized potential of more electronegative than -1,200 mV/CSE is considered as over-protection to the structure.

The summary of the potential measurement results is presented in Table 2 below.

**Table 2: Summary of Potential Measurements Result**

	Survey
Total number of test Points	70
Total number of unavailable potential measurements	2
Total number of potential measurements	68
Total number of potential measurements satisfying NACE criteria	32
Total number of Instant OFF potential measurements less electronegative than -850 mV	36
Percentage of potential measurements satisfying NACE Criteria	47%

The potential measurement datasheet is presented in Appendix B.

## 7. CONCLUSIONS

---

Based on evaluation of the rectifier data Corrpro makes the following conclusions:

- A total of nine (9) rectifiers are providing a total of one hundred and eighty-eight (188) amps of protective current to utilities site plan.
- A total 32 of 68 (47%) of potential readings gathered on this survey meet the NACE polarized potential criteria.
- The three ICCP rectifiers – R1 Unit 1, R-2 Unit 1, R-3 Unit 1 produced a total of 116.7 amps of cathodic protection current.
- The two ICCP rectifiers - R4 Unit 5, R-1 Unit 6-7 produced a total of 2.3 amps of cathodic protection current.
- For Units 1-4, only 6 out of the 26 test points are meeting the NACE polarized potential criteria. 4 of the 6 test points meeting the criteria are associated with the Fence. It is important to note that lines associated with Unit #1, #2, #3 and 4 are not meeting the NACE Criteria.

## 8. RECOMMENDATIONS

---

Based on the above conclusions Corrpro provides the following recommendations:

- Replace the broken test lead at Unit 5 Test station #43.
- Complete the missing potential measurements at Unit 6-7 test point #13, #15 to provide the complete cathodic protection data for the utilities site plan.
- Adjust the rectifier settings until the optimal cathodic protection current is achieved. It is recommended that bi-monthly surveys are conducted to ensure the optimal rectifier settings as the adjustments are made.

- Continue the annual cathodic protection survey to ensure continuous cathodic protection.

## APPENDIX A: CP POWER SOURCE DATA

# Cathodic Protection Survey

## Rectifier Data Sheet



### Appendix B

Rectifier ID  Job No.  Customer  Date

Location  Inspector  DC Rating  Volts  Amps

Mfg  Serial No.  AC Rating  Volts  Phase

Type (circle one): Air

Shunt Rating   Amps Tap Range  Coarse  Fine

#### CALIBRATION AND ADJUSTMENT

As Found

Rectifier Meter	DC VOLTS <input type="text" value="8.8"/>	DC AMPERES <input type="text" value="15.8"/>	Coarse	TAP SETTING <input type="text" value="1"/>	Fine	<input type="text" value="2"/>
Test Meter	<input type="text"/>	<input type="text"/>				

As Left

Rectifier Meter	DC VOLTS <input type="text" value="8.8"/>	DC AMPERES <input type="text" value="15.8"/>	Coarse	TAP SETTING <input type="text" value="1"/>	Fine	<input type="text" value="2"/>
Test Meter	<input type="text"/>	<input type="text"/>				

#### GROUND BED INSPECTION

Junction Box Condition  Vent

ANODE CURRENT OUTPUT (Amps)				Ground Bed and Anode Details	
1. <input type="text" value="2.52"/>	6. <input type="text"/>	11. <input type="text"/>	16. <input type="text"/>	Anode Type <input type="text"/>	
2. <input type="text" value="3.56"/>	7. <input type="text"/>	12. <input type="text"/>	17. <input type="text"/>	Max. Output Rating/Anode	<input type="text"/> Amps
3. <input type="text" value="3.64"/>	8. <input type="text"/>	13. <input type="text"/>	18. <input type="text"/>	Install Date	<input type="text"/>
4. <input type="text" value="3.08"/>	9. <input type="text"/>	14. <input type="text"/>	19. <input type="text"/>	G/B Configuration	<input type="text"/>
5. <input type="text" value="2.96"/>	10. <input type="text"/>	15. <input type="text"/>	20. <input type="text"/>	Depth/Length	<input type="text"/> Ft.
Total		15.76			

#### RECTIFIER OUTPUT HISTORY

RECTIFIER OUTPUT HISTORY						
Taps	DC Output		Shunt (mV)	Date	Reader	Comments
	Volts	Amps				

Remarks:

Photo:



# Cathodic Protection Survey

## Rectifier Data Sheet



### Appendix B

Rectifier ID  Job No.  Customer  Date

Location  Inspector  DC Rating  Volts  Amps

Mfg  Serial No.  AC Rating  Volts  Phase

Type (circle one): Air

Shunt Rating   Amps Tap Range  Coarse  Fine

#### CALIBRATION AND ADJUSTMENT

As Found

Rectifier Meter	DC VOLTS <input type="text" value="15.1"/>	DC AMPERES <input type="text" value="17.9"/>	Coarse	TAP SETTING <input type="text" value="1"/>	Fine	<input type="text" value="4"/>
Test Meter	<input type="text"/>	<input type="text"/>				

As Left

Rectifier Meter	DC VOLTS <input type="text" value="15.1"/>	DC AMPERES <input type="text" value="17.9"/>	Coarse	TAP SETTING <input type="text" value="1"/>	Fine	<input type="text" value="4"/>
Test Meter	<input type="text"/>	<input type="text"/>				

#### GROUND BED INSPECTION

Junction Box Condition  Vent

ANODE CURRENT OUTPUT (Amps)

1. <input type="text" value="5.70"/>	6. <input type="text"/>	11. <input type="text"/>	16. <input type="text"/>
2. <input type="text" value="8.65"/>	7. <input type="text"/>	12. <input type="text"/>	17. <input type="text"/>
3. <input type="text" value="3.55"/>	8. <input type="text"/>	13. <input type="text"/>	18. <input type="text"/>
4. <input type="text"/>	9. <input type="text"/>	14. <input type="text"/>	19. <input type="text"/>
5. <input type="text"/>	10. <input type="text"/>	15. <input type="text"/>	20. <input type="text"/>
Total		17.90	

Ground Bed and Anode Details

Max. Output Rating/Anode	<input type="text"/>	Amps
Install Date	<input type="text"/>	
G/B Configuration	<input type="text"/>	
Depth/Length	<input type="text"/>	Ft.

#### RECTIFIER OUTPUT HISTORY

DC Output						
Taps	Volts	Amps	Shunt (mV)	Date	Reader	Comments

Remarks:

Photo:

# Cathodic Protection Survey

## Rectifier Data Sheet



### Appendix B

Rectifier ID  Job No.  Customer  Date

Location  Inspector  DC Rating  Volts  Amps

Mfg  Serial No.  AC Rating  Volts  Phase

Type (circle one): Air

Shunt Rating  Volts  Amps Tap Range  Coarse  Fine

#### CALIBRATION AND ADJUSTMENT

As Found

Rectifier Meter	DC VOLTS <input type="text" value="5.5"/>	DC AMPERES <input type="text" value="21.2"/>	Coarse	TAP SETTING <input type="text" value="2"/>	Fine	<input type="text" value="2"/>
Test Meter	<input type="text"/>	<input type="text"/>				

As Left

Rectifier Meter	DC VOLTS <input type="text" value="5.5"/>	DC AMPERES <input type="text" value="21.2"/>	Coarse	TAP SETTING <input type="text" value="2"/>	Fine	<input type="text" value="2"/>
Test Meter	<input type="text"/>	<input type="text"/>				

#### GROUND BED INSPECTION

Junction Box Condition  Vent

ANODE CURRENT OUTPUT (Amps)				Ground Bed and Anode Details	
1. <input type="text"/>	6. <input type="text"/>	11. <input type="text"/>	16. <input type="text"/>	Anode Type <input type="text"/>	
2. <input type="text"/>	7. <input type="text"/>	12. <input type="text"/>	17. <input type="text"/>	Max. Output Rating/Anode	<input type="text"/> Amps
3. <input type="text"/>	8. <input type="text"/>	13. <input type="text"/>	18. <input type="text"/>	Install Date	<input type="text"/>
4. <input type="text"/>	9. <input type="text"/>	14. <input type="text"/>	19. <input type="text"/>	G/B Configuration	<input type="text"/>
5. <input type="text"/>	10. <input type="text"/>	15. <input type="text"/>	20. <input type="text"/>	Depth/Length	<input type="text"/> Ft.
Total		0.00			

#### RECTIFIER OUTPUT HISTORY

DC Output						
Taps	Volts	Amps	Shunt (mV)	Date	Reader	Comments

Remarks:

Photo:

# Cathodic Protection Survey

## Rectifier Data Sheet



### Appendix B

Rectifier ID  Job No.  Customer  Date

Location  Inspector  DC Rating  Volts  Amps

Mfg  Serial No.  AC Rating  Volts  Phase

Type (circle one): Air

Shunt Rating  Volts  Amps Tap Range  Coarse  Fine

#### CALIBRATION AND ADJUSTMENT

As Found

Rectifier Meter	DC VOLTS <input type="text" value="3.8"/>	DC AMPERES <input type="text" value="0.7"/>	Coarse	TAP SETTING <input type="text" value="1"/>	Fine	<input type="text" value="1"/>
Test Meter	<input type="text"/>	<input type="text"/>				

As Left

Rectifier Meter	DC VOLTS <input type="text" value="3.8"/>	DC AMPERES <input type="text" value="0.7"/>	Coarse	TAP SETTING <input type="text" value="1"/>	Fine	<input type="text" value="1"/>
Test Meter	<input type="text"/>	<input type="text"/>				

#### GROUND BED INSPECTION

Junction Box Condition  Vent

ANODE CURRENT OUTPUT (Amps)				Ground Bed and Anode Details	
1. <input type="text"/>	6. <input type="text"/>	11. <input type="text"/>	16. <input type="text"/>	Anode Type <input type="text"/>	
2. <input type="text"/>	7. <input type="text"/>	12. <input type="text"/>	17. <input type="text"/>	Max. Output Rating/Anode	<input type="text"/> Amps
3. <input type="text"/>	8. <input type="text"/>	13. <input type="text"/>	18. <input type="text"/>	Install Date	<input type="text"/>
4. <input type="text"/>	9. <input type="text"/>	14. <input type="text"/>	19. <input type="text"/>	G/B Configuration	<input type="text"/>
5. <input type="text"/>	10. <input type="text"/>	15. <input type="text"/>	20. <input type="text"/>	Depth/Length	<input type="text"/> Ft.
Total		0.00			

#### RECTIFIER OUTPUT HISTORY

DC Output						
Taps	Volts	Amps	Shunt (mV)	Date	Reader	Comments

Remarks:

Photo:

# Cathodic Protection Survey

## Rectifier Data Sheet



### Appendix B

Rectifier ID  Job No.  Customer  Date

Location  Inspector  DC Rating  Volts  Amps

Mfg  Serial No.  AC Rating  Volts  Phase

Type (circle one): Air

Shunt Rating  Volts  Amps Tap Range  Coarse  Fine

#### CALIBRATION AND ADJUSTMENT

As Found

Rectifier Meter	DC VOLTS <input type="text" value="5.7"/>	DC AMPERES <input type="text" value="1.6"/>	Coarse	TAP SETTING <input type="text" value="1"/>	Fine	<input type="text" value="4"/>
Test Meter	<input type="text"/>	<input type="text"/>				

As Left

Rectifier Meter	DC VOLTS <input type="text" value="5.7"/>	DC AMPERES <input type="text" value="1.6"/>	Coarse	TAP SETTING <input type="text" value="1"/>	Fine	<input type="text" value="4"/>
Test Meter	<input type="text"/>	<input type="text"/>				

#### GROUND BED INSPECTION

Junction Box Condition  Vent

ANODE CURRENT OUTPUT (Amps)				Ground Bed and Anode Details	
1. <input type="text" value="0.30"/>	6. <input type="text"/>	11. <input type="text"/>	16. <input type="text"/>	Anode Type <input type="text"/>	
2. <input type="text" value="0.20"/>	7. <input type="text"/>	12. <input type="text"/>	17. <input type="text"/>	Max. Output Rating/Anode	<input type="text"/> Amps
3. <input type="text" value="0.30"/>	8. <input type="text"/>	13. <input type="text"/>	18. <input type="text"/>	Install Date	<input type="text"/>
4. <input type="text" value="0.30"/>	9. <input type="text"/>	14. <input type="text"/>	19. <input type="text"/>	G/B Configuration	<input type="text"/>
5. <input type="text" value="0.40"/>	10. <input type="text"/>	15. <input type="text"/>	20. <input type="text"/>	Depth/Length	<input type="text"/> Ft.
Total		1.50			

#### RECTIFIER OUTPUT HISTORY

RECTIFIER OUTPUT HISTORY						
Taps	DC Output		Shunt (mV)	Date	Reader	Comments
	Volts	Amps				

Remarks:

Photo:

# Cathodic Protection Survey

## Rectifier Data Sheet



### Appendix B

Rectifier ID  Job No.  Customer  Date

Location  Inspector  DC Rating  Volts  Amps

Mfg  Serial No.  AC Rating  Volts  Phase

Type (circle one): Air

Shunt Rating  Volts  Amps Tap Range  Coarse  Fine

#### CALIBRATION AND ADJUSTMENT

As Found

Rectifier Meter	DC VOLTS <input type="text" value="14.5"/>	DC AMPERES <input type="text" value="38.6"/>	TAP SETTING	
Test Meter	<input type="text"/>	<input type="text"/>	Coarse <input type="text" value="1"/>	Fine <input type="text" value="5"/>

As Left

Rectifier Meter	DC VOLTS <input type="text" value="14.5"/>	DC AMPERES <input type="text" value="38.6"/>	TAP SETTING	
Test Meter	<input type="text"/>	<input type="text"/>	Coarse <input type="text" value="1"/>	Fine <input type="text" value="5"/>

#### GROUND BED INSPECTION

Junction Box Condition  Vent

ANODE CURRENT OUTPUT (Amps)				Ground Bed and Anode Details	
1. <input type="text"/>	6. <input type="text"/>	11. <input type="text"/>	16. <input type="text"/>	Max. Output Rating/Anode <input type="text"/> Amps	Anode Type <input type="text"/>
2. <input type="text"/>	7. <input type="text"/>	12. <input type="text"/>	17. <input type="text"/>		
3. <input type="text"/>	8. <input type="text"/>	13. <input type="text"/>	18. <input type="text"/>		
4. <input type="text"/>	9. <input type="text"/>	14. <input type="text"/>	19. <input type="text"/>		
5. <input type="text"/>	10. <input type="text"/>	15. <input type="text"/>	20. <input type="text"/>		
Total		0.00		Install Date <input type="text"/>	
				G/B Configuration <input type="text"/>	
				Depth/Length <input type="text"/> Ft.	

#### RECTIFIER OUTPUT HISTORY

DC Output						
Taps	Volts	Amps	Shunt (mV)	Date	Reader	Comments

Remarks:

Photo:

# Cathodic Protection Survey

## Rectifier Data Sheet



### Appendix B

Rectifier ID  Job No.  Customer  Date

Location  Inspector  DC Rating  Volts  Amps

Mfg  Serial No.  AC Rating  Volts  Phase

Type (circle one): Air

Shunt Rating  Volts  Amps Tap Range  Coarse  Fine

#### CALIBRATION AND ADJUSTMENT

As Found

Rectifier Meter	DC VOLTS <input type="text" value="18.6"/>	DC AMPERES <input type="text" value="33.7"/>	Coarse	TAP SETTING <input type="text" value="1"/>	Fine	<input type="text" value="4"/>
Test Meter	<input type="text"/>	<input type="text"/>				

As Left

Rectifier Meter	DC VOLTS <input type="text" value="18.6"/>	DC AMPERES <input type="text" value="33.7"/>	Coarse	TAP SETTING <input type="text" value="1"/>	Fine	<input type="text" value="4"/>
Test Meter	<input type="text"/>	<input type="text"/>				

#### GROUND BED INSPECTION

Junction Box Condition  Vent

ANODE CURRENT OUTPUT (Amps)				Ground Bed and Anode Details	
1. <input type="text" value="10.08"/>	6. <input type="text"/>	11. <input type="text"/>	16. <input type="text"/>	Anode Type <input type="text"/>	
2. <input type="text" value="0.08"/>	7. <input type="text"/>	12. <input type="text"/>	17. <input type="text"/>	Max. Output Rating/Anode	<input type="text"/> Amps
3. <input type="text" value="7.60"/>	8. <input type="text"/>	13. <input type="text"/>	18. <input type="text"/>	Install Date	<input type="text"/>
4. <input type="text" value="8.84"/>	9. <input type="text"/>	14. <input type="text"/>	19. <input type="text"/>	G/B Configuration	<input type="text"/>
5. <input type="text" value="7.28"/>	10. <input type="text"/>	15. <input type="text"/>	20. <input type="text"/>	Depth/Length	<input type="text"/> Ft.
Total		33.88			

#### RECTIFIER OUTPUT HISTORY

RECTIFIER OUTPUT HISTORY						
Taps	DC Output		Shunt (mV)	Date	Reader	Comments
	Volts	Amps				

Remarks:

Photo:



# Cathodic Protection Survey

## Rectifier Data Sheet



### Appendix B

Rectifier ID  Job No.  Customer  Date

Location  Inspector  DC Rating  Volts  Amps

Mfg  Serial No.  AC Rating  Volts  Phase

Type (circle one): Air

Shunt Rating  Volts  Amps Tap Range  Coarse  Fine

#### CALIBRATION AND ADJUSTMENT

As Found

Rectifier Meter	DC VOLTS <input type="text" value="18.4"/>	DC AMPERES <input type="text" value="44.4"/>	Coarse	TAP SETTING <input type="text" value="1"/>	Fine	<input type="text" value="4"/>
Test Meter	<input type="text"/>	<input type="text"/>				

As Left

Rectifier Meter	DC VOLTS <input type="text" value="18.4"/>	DC AMPERES <input type="text" value="44.4"/>	Coarse	TAP SETTING <input type="text" value="1"/>	Fine	<input type="text" value="4"/>
Test Meter	<input type="text"/>	<input type="text"/>				

#### GROUND BED INSPECTION

Junction Box Condition  Vent

ANODE CURRENT OUTPUT (Amps)				Ground Bed and Anode Details	
1. <input type="text" value="9.20"/>	6. <input type="text"/>	11. <input type="text"/>	16. <input type="text"/>	Max. Output Rating/Anode <input type="text"/> Amps	Anode Type <input type="text"/>
2. <input type="text" value="8.40"/>	7. <input type="text"/>	12. <input type="text"/>	17. <input type="text"/>		Install Date <input type="text"/>
3. <input type="text" value="9.08"/>	8. <input type="text"/>	13. <input type="text"/>	18. <input type="text"/>		G/B Configuration <input type="text"/>
4. <input type="text" value="7.52"/>	9. <input type="text"/>	14. <input type="text"/>	19. <input type="text"/>		Depth/Length <input type="text"/> Ft.
5. <input type="text" value="7.16"/>	10. <input type="text"/>	15. <input type="text"/>	20. <input type="text"/>		
Total		41.36			

#### RECTIFIER OUTPUT HISTORY

DC Output						
Taps	Volts	Amps	Shunt (mV)	Date	Reader	Comments

Remarks:

Photo:

# Cathodic Protection Survey

## Rectifier Data Sheet



### Appendix B

Rectifier ID  Job No.  Customer  Date

Location  Inspector  DC Rating  Volts  Amps

Mfg  Serial No.  AC Rating  Volts  Phase

Type (circle one): Air

Shunt Rating  Volts  Amps Tap Range  Coarse  Fine

#### CALIBRATION AND ADJUSTMENT

As Found

Rectifier Meter	DC VOLTS <input type="text" value="8.4"/>	DC AMPERES <input type="text" value="14.6"/>	Coarse	TAP SETTING <input type="text" value="2"/>	Fine	<input type="text" value="3"/>
Test Meter	<input type="text"/>	<input type="text"/>				

As Left

Rectifier Meter	DC VOLTS <input type="text" value="8.4"/>	DC AMPERES <input type="text" value="14.6"/>	Coarse	TAP SETTING <input type="text" value="2"/>	Fine	<input type="text" value="3"/>
Test Meter	<input type="text"/>	<input type="text"/>				

#### GROUND BED INSPECTION

Junction Box Condition  Vent

ANODE CURRENT OUTPUT (Amps)				Ground Bed and Anode Details	
1. <input type="text"/>	6. <input type="text"/>	11. <input type="text"/>	16. <input type="text"/>	Anode Type <input type="text"/>	
2. <input type="text"/>	7. <input type="text"/>	12. <input type="text"/>	17. <input type="text"/>	Max. Output Rating/Anode	<input type="text"/> Amps
3. <input type="text"/>	8. <input type="text"/>	13. <input type="text"/>	18. <input type="text"/>	Install Date	<input type="text"/>
4. <input type="text"/>	9. <input type="text"/>	14. <input type="text"/>	19. <input type="text"/>	G/B Configuration	<input type="text"/>
5. <input type="text"/>	10. <input type="text"/>	15. <input type="text"/>	20. <input type="text"/>	Depth/Length	<input type="text"/> Ft.
Total		0.00			

#### RECTIFIER OUTPUT HISTORY

DC Output						
Taps	Volts	Amps	Shunt (mV)	Date	Reader	Comments

Remarks:

Photo:

## **APPENDIX B: POTENTIAL MEASUREMENT DATA**

## Appendix A

[illegible]

## Appendix A

[illegible]


## Appendix A


[illegible]



## **APPENDIX C: SITE WIDE MAPS**





12. UNLESS OTHERWISE SHOWN AS ABOVEGROUND, INSIDE OF VAULTS OR STUB-UPS, ALL PIPING IS UNDERGROUND.
13. PROVIDE TRACER WIRE ALONG ALL BURIED NONMETALLIC PIPING PER THE SPECIFICATIONS.
14. FOR EXCAVATION AND BACK FILLING FOR UNDERGROUND PIPING REFER TO SPECIFICATIONS SECTION 02200, "EARTHWORK".
15. COORDINATE THE INSTALLATION OF THE UNDERGROUND UTILITIES WITH THE ELECTRICAL DUCT BANKS AND THE STRUCTURAL FOUNDATIONS. EXCEPT WHERE SPECIFICALLY NOTED AND SHOWN ON THE UNDERGROUND UTILITY PLAN DRAWING, ALL UNDERGROUND PIPING IS RUN ABOVE THE ELECTRICAL DUCT BANKS. REFER TO THE ELECTRICAL DRAWINGS FOR THE SPECIFIC TOP AND BOTTOM ELEVATIONS OF THE ELECTRICAL DUCT BANKS.
16. PROVIDE SHORING AND SHEETING IN TRENCH EXCAVATIONS AS REQUIRED TO PREVENT INJURY TO PERSONS AND DAMAGE TO STRUCTURES PER ALL APPLICABLE OSHA AND LOCAL CODES.
17. FOR TYPICAL DRAIN VALVE BOX DETAIL SEE 
18. FITTINGS IN HDPE PIPING SYSTEMS SHALL BE STANDARD FABRICATED OR MOLDED FITTINGS OR CUSTOM FABRICATED AS REQUIRED WHERE NECESSARY FOR THE PIPING SYSTEMS TO CONFORM TO CONSTRICTED OR LIMITED SPACED AREAS IN THE INSTALLATION.
19. FIELD VERIFY LOCATION AND DEPTH OF EXTG. UNDERGROUND PIPING AND MAKE NECESSARY ADJUSTMENTS TO NEW PIPING DEPTH AS REQUIRED TO CLEAR ANY POSSIBLE OBSTRUCTION.

ACW	AUXILIARY COOLING WATER		FEATURES BY OTHER DISCIPLINES OR I.I.C.
AG	ABOVE GROUND		NEW PIPING AND RELATED FEATURES
BF	BLIND FLANGE		
BOD	BOTTOM OF DUCT ELEVATION		SERVICE TIE-IN POINT
BOP	BOTTOM OF PIPE ELEVATION		EQUIPMENT DRAIN STUB-UP WITH DRAIN FUNNEL
C	CONDENSATE		
CHW	CHILLED WATER		PROCESS PIPING STUB UP - SIZE 4" AND BELOW
CO	CLEANOUT		PROCESS PIPING STUB UP - SIZE 6" AND ABOVE
CW	COOLING WATER (EXTG. PLANT)		
DI	DEMINERALIZED WATER		
ECC	ECCENTRIC		CLEAN OUT
ED	EQUIPMENT DRAIN		
(E)	EXISTING	HYD.	FIRE HYDRANT
EL	ELEVATION		GUARD POST (BOLLARD)
EW	EACH WAY		GATE VALVE
FOB	FLAT ON BOTTOM		
FOF	FACE OF FLANGE	(REF)	DATA MUST BE VERIFIED IN FIELD
FS	FIRE SERVICE	<u>E7970'</u>	COORDINATE DIMENSION
IA	INSTRUMENT AIR		
INV	INVERT ELEVATION		DRAIN VALVE BOX
HDPE	HIGH DENSITY POLYETHYLENE		
(N)	NEW		
NG	NATURAL GAS		
NH3	AMMONIA		
N.T.S.	NOT TO SCALE		
O.D.	OUTSIDE DIAMETER		
PA	PLANT AIR		
PIV	POST INDICATING VALVE		
PW	POTABLE WATER		
RED	REDUCER		
RIM	DRAIN FUNNEL RIM ELEVATION		
RW	RAW WATER		
SS	SANITARY SEWER		
TOC	TOP OF CONCRETE ELEVATION		
TOD	TOP OF DUCT ELEVATION		
TOP	TOP OF PIPE ELEVATION		
TYP.	TYPICAL		
UG	UNDERGROUND		
U.O.N.	UNLESS OTHERWISE NOTED		
WWD	WATER WASH DRAIN (GRAVITY)		
WW	WATER WASH DRAIN (PUMPED)		


2	5-7-10	AS BUILT		SK	JKJ
1	6-26-09	REMOVED HOLD & REVISED AS NOTED		JJB	RS
0	5-26-09	ISSUED FOR CONSTRUCTION		JJB	RS
SAMPLE	DATE	REVISION DESCRIPTION		DRAWN	APP'D




SAND HILL ENERGY CENTER 100MW EXPANSION PROJECT  
AUSTIN, TEXAS

UNDERGROUND UTILITIES SITE PLAN  
KEY PLAN, LEGEND AND NOTES


DR. JJB	APPROVED _____ DATE _____	DRAWING NO.	RE
DES. JJB		C4.0	2
CHK. GW		PRINCIPAL IN CHARGE _____ DATE _____	SHEET _____ OF _____







- NOTES:
1. FOR UNDERGROUND UTILITIES NOTES AND LEGEND SEE DRAWING C4.0.
  2. DRAIN VALVE BOX THESE LOCATIONS SHALL BE INSTALLED SIMILAR TO THE DRAIN VALVE BOX DETAIL ON DWG. C5.1 EXCEPT THAT IT SHALL BE A CHRSITY MODEL B36 WITH WATCHING REQUIRED ACCESSORIES TO PROVIDE ACCESS TO DRAIN VALVE AT GREATER DEPTH. ALTERNATE TO TWO B36 BOXES, ONE LARGER BOX MAY BE PROVIDED TO GIVE THE REQUIRED ACCESS TO THE VALVE.



4	5-7-10	AS BUILT	SK	JKJ
3	8-3-09	REVISED AS NOTED	JUB	RS
2	7-16-09	REVISED AS NOTED & REMOVED HOLD	JUB	RS
1	6-26-09	REVISED AS NOTED	JUB	RS
0	5-26-09	ISSUED FOR CONSTRUCTION	JUB	RS
SYMBOL		DATE	REVISION DESCRIPTION	DRAWN APP'D

**PB Power**  
A Parsons Brinckerhoff Company  
303 SECOND STREET, SUITE 700 NORTH, SAN FRANCISCO, CALIFORNIA 94107

**TIC**  
The Industrial Company.


**AUSTIN ENERGY**

SAND HILL ENERGY CENTER 100MW EXPANSION PROJECT  
AUSTIN, TEXAS


UNDERGROUND UTILITIES PLAN - AREA 1




DR. JUB	APPROVED	DATE	DRAWING NO.	REV
DES. JUB			C4.1	4
CHK. GW	PRINCIPAL IN CHARGE	DATE	SHEET	OF












		<b>PB Power</b> A Parsons Brinckerhoff Company 303 SECOND STREET, SUITE 700 NORTH, SAN FRANCISCO, CALIFORNIA 94107	
 <b>The Industrial Company,</b>			
			
SAND HILL ENERGY CENTER 100MW EXPANSION PROJECT AUSTIN, TEXAS			
UNDERGROUND UTILITIES PLAN — AREA 3			
DR. JJB DES. JJB CHK. GW	APPROVED _____ DATE _____  PRINCIPAL IN CHARGE _____ DATE _____	DRAWING NO. <b>C4.3</b>	REV. 6
		SHEET	OF





- NOTES:**
- FOR UNDERGROUND UTILITIES NOTES AND LEGEND SEE DRAWING C4.0.
  - FIELD VERIFY LOCATION AND DEPTH OF EXIST. UNDERGROUND PIPING AND MAKE NECESSARY ADJUSTMENTS TO NEW PIPING DEPTH AS REQUIRED TO CLEAR ANY POSSIBLE OBSTRUCTION.



6	5-7-10	AS BUILT	SK	JKJ
5	8-26-09	REVISED PER RFI #024	JUB	RS
4	8-5-09	REVISED AS NOTED	JUB	RS
3	7-17-09	REVISED PER RFI #011, DRAIN REMO'D	JUB	RS
2	7-16-09	REVISED AS NOTED & REMOVED HOLD	JUB	RS
1	6-26-09	REVISED AS NOTED	JUB	RS
0	5-26-09	ISSUED FOR CONSTRUCTION	JUB	RS
S	DATE	REVISION DESCRIPTION	DRAWN	APPTD

**PB Power**  
A Parsons Brinckerhoff Company  
303 SECOND STREET, SUITE 700 NORTH, SAN FRANCISCO, CALIFORNIA 94107

**TIC**  
The Industrial Company.

**AUSTIN ENERGY**

SAND HILL ENERGY CENTER 100MW EXPANSION PROJECT  
AUSTIN, TEXAS

UNDERGROUND UTILITIES PLAN - AREA 4

DR. JUB	APPROVED	DATE	DRAWING NO.	REV
DES. JUB			C4.4	6
CHK. GW	PRINCIPAL IN CHARGE	DATE	SHEET	OF



## **APPENDIX D: TESTING PROCEDURES**

The following test procedures were utilized during the cathodic protection evaluation and are in accordance with industry standards.

- Visual Inspection
- Rectifier Electrical Inspection
- Structure-to-Potential Measurements

### **1. VISUAL INSPECTION**

Corrpro performed a visual inspection of CP components (rectifiers, anode junction boxes, etc.) for physical or electrical damage and assessment of condition. This assessment is included in the report.

### **2. RECTIFIER ELECTRICAL INSPECTION**

Assessment of operating condition of the rectifiers, including inspection for physical or electrical damage, verification of meter accuracy and general assessment of the rectifier condition was performed. Generated data and results are included within the appendix of this report. Rectifier voltage and current outputs were recorded using the built-in meters within the unit and verified utilizing a calibrated high impedance digital multi-meter by reading across the individual output lugs and calibrated measuring shunts.

### **3. STRUCTURE-TO-POTENTIAL MEASUREMENTS**

Structure-to-soil potential measurements are used to determine the level of CP being provided to a structure by measuring the potential difference (voltage) between the structure and a reference electrode. A calibrated stationary CSE placed in soil adjacent to the structure is utilized. When the potential difference between the reference electrode and the structure meets one of the NACE recognized criteria, CP has been achieved on the structure in the vicinity of the reference electrode.

#### **3.1. ON-POTENTIAL MEASUREMENTS**

The application of CP current to a structure will cause the structure-to-soil potential values to become more negative. Potentials measured with CP current applied to the structure are referred to as on potential measurements. In cathodic protection systems with large current requirement, the on potential measurements can include an IR drop error. This error can cause erroneous results and must be considered when evaluating the potential value. IR consideration was in the form of comparison to previously established IR at each test point location.

### **3.2. INSTANT OFF-POTENTIAL MEASUREMENTS**

The instant-off potential is also known as the polarized potential because the measurement is made immediately upon current interruption. Because there is no externally applied current, the IR-drop error is negligible.

## **4. TEST EQUIPMENT**

### Digital Voltmeter

A calibrated high impedance digital multi-feature voltmeter was used for the voltage and amperage output tests. The meter was a multi-scale, 10 M $\Omega$  input impedance, accurate to within one percent of full scale, covering the following full-scale ranges: 0-10 and 0-100 millivolts; 0-1, 0-10, 0-100 volts.

### Stationary Copper/Copper Sulfate Reference Electrode

A calibrated stationary CSE was utilized for all potential readings on CP system to obtain measurements that most accurately represent the environment along the pipeline system.