



**ADDENDUM
PURCHASING OFFICE
CITY OF AUSTIN, TEXAS**

Solicitation: IFB TVN1028

Addendum No: 1

Date of Addendum: 8/10/2020

This addendum is to incorporate the following changes to the above referenced solicitation:

I. Questions:

I.1 Per specification E-0902, Sections:

- 4.6.1 The design shall minimize the number of series/parallel connections to re-configure the capacitor bank for a change in the operating voltage.
- 4.6.2 Changing the operating voltage of the capacitor bank shall not require re-stacking the capacitor units/sections.
- 4.6.3 The capacitor bank shall maintain the 31.2 MVAR rating at either operating voltage
What would be the new operating voltage(s) after a re-configuration of the bank?

For 138 kV nominal, the operating voltage should be 151.8/124.2 kV.(±10%)

II. Additional Information: Section 6.1.8 has been replaced by the following (new requirement in **RED):**

6.1.8 The following spare equipment shall be furnished with each complete capacitor bank shipped:

- 1) Three (3) capacitor units
- 2) Three (3) individual fuse assemblies
- 3) Twenty (20) fuse links

The price of the spare equipment shall be included in the bid price.

Contractor shall provide a list of recommended spare parts with pricing. This information will not be considered in the price evaluation.

III. ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.

ACKNOWLEDGED BY:

Name

Authorized Signature

Date

RETURN ONE COPY OF THIS ADDENDUM TO THE PURCHASING OFFICE, CITY OF AUSTIN, WITH YOUR RESPONSE OR PRIOR TO THE SOLICITATION CLOSING DATE. FAILURE TO DO SO MAY CONSTITUTE GROUNDS FOR REJECTION.